

DAN'S
ACTION
LIST

ON these types of SOPs, you keep
SOP BUT IF ITEM IS UNACCEPTABLE SEND TO SOP
FOR ACTION/NOTIFICATION/DECISIONS, AND RETURN TO
SERVICE

Direct Potable Water Reuse Standard Operating Procedure

Wichita Falls, Texas

RIVER ROAD PETROLEUM DETECTED IN SECONDARY CLARIFIERS

This SOP supersedes any previous SOP on this topic. ^Effective on the date signed approved below.

INTRODUCTION

This is the Standard Operating Procedures for detection of Petroleum in the River Road WWTP.

OBJECTIVE

The objective of this document is to prevent petroleum products from entering the transfer of water to the Cypress DPR.

Petroleum sheen visible in the Secondary clarifiers.

- This will be confirmed by a visible oily sheen on the surface of a Secondary Clarifiers along with a sniff test done on a sample taken from the Secondary Clarifier.
- This observation must be confirmed by two persons in agreement at the same time.
- A sample of the suspected water will be caught and kept if need for analysis.
- If it is agreed upon that there is petroleum in the water the Operations Supervisor will be notified, and the decision to shut down will begin.

How much?

Related SOP: RIVER ROAD SHUTDOWN COMMUNICATION PROTOCOL

Prepared By: Bill Thornton

Prepared Date: May 6, 2014

Approved by: _____

Approved Date: _____

Reviewed by: _____

Reviewed Date: _____

*SOP's are to be reviewed and/or updated annually or any time this process has changed.

RIVER ROAD PETROLEUM DETECTED IN SECONDARY CLARIFIERS

Sign below and date that you have received training on this SOP. By signing you are stating that you understand and will differ to this SOP when applicable.

Name	Signature	date	Signature	date
David Souilliere			Mark Huggins	
Johnny Chavez			Ron Kendrick	
Katharine DeMars			Rodney Allen	
Paul Blackwell			McIlvanie	
Ian fox			Diana Graham	
Paul Carr			Damon Halper	
Orville Sosebee			Jessie Martin	
Orlando Simpliciano			James Seigler	
Cheryl Chaney				