

Davis MAYBE AN ACTION Items

Direct Potable Water Reuse Standard Operating Procedure

Wichita Falls, Texas

HIGH DISSOLVED OXYGEN DEMAND AT RIVER ROAD WWTP

This SOP supersedes any previous SOP on this topic. Affective on the date signed approved below

INTRODUCTION

This is the Standard Operating Procedures for maintaining adequate Dissolved Oxygen in the Biological treatment of the River Road WWTP

OBJECTIVE

The objective of this document is to try and detect artificial Oxygen demand.

In the event that there is a high dissolved Oxygen demand in two or more Aeration Basins expressed by requiring an increase of air SCFM output greater than 40% (based on the last eight hours of flow and loading) for more than four hours to maintain the established D.O. set point. In addition, the cause of the increase in D.O. demand cannot be traced to any operational process or malfunction of equipment.

- The River Road WWTP will begin to take samples from the outfall of the affected aeration basins and test for abnormal pH, Alkalinity, (OUR)
- An Oxygen Uptake Rate measurement will be performed on each affected basin.
- If the pH is less than or greater than 1 of the daily reported, or the Alkalinity, or the OUR is less than or greater than 40% of the daily uptake rate the test will be repeated in one hour.
- If after the second testing the results are in the same range, a microscopic exam will be done on each of the affected basins to confirm if there is any toxic effect on the organisms.
- If a toxic effect is observed refer to section on Microscopic exam.
- If the microscopic exam is acceptable, a portion of each of the secondary clarifier composite samples will be kept in approved sample containers for toxicity testing.
- The Cypress DPR will be notified of the situation.
- If after eight hours from the start of the event there has been no recovery of the D.O demand as indicated by the return to normal airflow SCFM in the aeration basins the Operations Supervisor will be notified and the decision to shut down will begin.

what does this mean?

what is meant by "acceptable"

what about alkalinity?
per SOP

WQT
convene
MAYBE
before
8 hrs

Related SOP: RIVER ROAD SHUTDOWN COMMUNICATION PROTOCOL

Prepared By: Bill Thornton

Prepared Date: May 6, 2014

Approved by: _____

Approved Date: _____

Reviewed by: _____

Reviewed Date: _____

*SOP's are to be reviewed and/or updated annually or any time this process has changed.

HIGH DISSOLVED OXYGEN DEMAND AT RIVER ROAD WWTP

Sign below and date that you have received training on this SOP. By signing you are stating that you understand and will differ to this SOP when applicable.

Name	Signature	date	Signature	date
David Souilliere			Mark Huggins	
Johnny Chavez			Ron Kendrick	
Katharine DeMars			Rodney Allen	
Paul Blackwell			McIlvanie	
Ian fox			Diana Graham	
Paul Carr			Damon Halper	
Orville Sosebee			Jessie Martin	
Orlando Simpliciano			James Seigler	
Cheryl Chaney				