

Effluent Violations for Select Facility
12/31/2010 through 12/31/2013

*** NOT ICIS CERTIFIED ***

TPDES ID	NPDES ID	Facility Name	CMC Name	Enf Auth	Major/Minor	92-500	TCEQ Region	Issue Date	Expiration Date	Primary SIC
10509001	TX0047686	RIVER ROAD WWTF	AGUILA	STATE	Major			5/10/2007	12/1/2010	4952
10509001	TX0047686	RIVER ROAD WWTF	KNEISLEY	STATE	Major			12/2/2010	12/1/2015	4952

Outfall No.	Limit Set Name	Limit Start Date	Limit End Date
001A	DOMESTIC FACILITY - 001	6/1/07	12/1/10

Monitoring Period	Pram_Cd	Parameter	MLOC	Limit (%Vio)	RNC Vio	Received Date	Limit (%Vio)	RNC Vio	Received Date
				15 DAILY AV (mg/L)			40 DAILY MX (mg/L)		
12/31/2010	00530	Solids, total suspended	1	16 (7%)		1/21/11	50 (25%)		1/21/11

Outfall No.	Limit Set Name	Limit Start Date	Limit End Date
001A	DOMESTIC FACILITY - 001	1/1/11	12/1/15

Monitoring Period	Pram_Cd	Parameter	MLOC	Limit (%Vio)	RNC Vio	Received Date
				7 DAILY MX (mg/L)		
7/31/2013	00610	Nitrogen, ammonia total [as N]	1	8.56 (22%)		8/13/13

Monitoring Period	Pram_Cd	Parameter	MLOC	Limit (%Vio)	RNC Vio	Received Date
				40 DAILY MX (mg/L)		
5/31/2011	00530	Solids, total suspended	1	47 (18%)		6/20/11