

Kathleen Hartnett White, *Chairman*
Larry R. Soward, *Commissioner*
Glenn Shankle, *Executive Director*



Tracer
PWS#2430001/CO
CN600129316
RN101611275

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

January 31, 2007

Mr. T. Dean Hinton, P.E.
Corlett, Probst & Boyd LLP
4605 Old Jacksboro Highway
Wichita Falls, Texas 76302

Subject: Public Drinking Water System
Requested CT Study for
City of Wichita Falls Cypress Street Water Treatment Plant – PWS ID No. 2430001
Wichita County, Texas

Dear Mr. Hinton:

We are in receipt of your letter, dated January 25, 2007, requesting a CT study to reflect the modifications at the City of Wichita Falls Lake Kemp Headquarters Raw Pump Station (HRPS) which feeds raw water to the Cypress Street Water Treatment Plant (WTP). In searching our CT study records, we discovered the Cypress Street WTP apparently never satisfied the condition in the Texas Commission on Environmental Quality (TCEQ) Plan Review Log No. 204-142 letter dated August 19, 2004, to submit a revised CT study to TCEQ. The CT study is necessary to assess the disinfection process at the modified Cypress Street WTP to ensure compliance with the disinfection requirements of the Surface Water Treatment Rule. Any revised CT study submitted for TCEQ review must receive approval prior to delivery of potable water to the customers, which satisfies 30 TAC §290.110(c)(1).

We are denying the revised CT study for the City of Wichita Falls Lake Kemp HRPS. Our records show the Cypress Street WTP has been operational, submitting surface water monthly operating reports since the end of WTP expansion that was conditionally approved in TCEQ Plan Review Log No. 204-142. The City of Wichita Falls Cypress Street WTP must submit a revised CT study to TCEQ within 60 days from the date of reception of this letter.

To help you complete your revised CT study, the TCEQ CT template with instructions is found on our web site at this link:

http://www.tceq.state.tx.us/permitting/water_supply/pdw/swmor/swmor/ct_zip.html

If you have any questions concerning our evaluation or if we may be of other assistance, please contact me at (512) 239-4729 or at the Commission's address on the letterhead.