

Industrial Contributions to the RR WWTP

In TCEQ's September 5, 2013 letter several suggestions about the industrial pretreatment program at the City was discussed. These suggestions have been placed in Enclosure H for your convenience.

Replacement of Reverse Osmosis Membrane Elements

On June 17, 2014, the TCEQ received your letter dated June 17, 2014, notifying us of the City's intent to replace the RO membrane elements in five RO trains. Because you propose to use membrane elements that are the same models as have been previously approved, the City will not be required to submit plans and specifications for the RO replacement project. Per discussion with City staff, the timeframe for replacement is summer 2014.

Replacement of Microfiltration Membrane Elements

On February 5, 2014, the TCEQ received your letter dated January 30, 2014 notifying us that the City had replaced the MF membrane elements in two MF units. The TCEQ received the challenge study for these MF membrane elements and has approved the study. The City will not be required to submit plans and specifications for the MF replacement project. In order to avoid future violations, please note the City is required by 30 TAC Chapter §290.39(j) to notify the TCEQ prior to making significant changes including membrane replacement.

If you have any questions regarding this letter, please contact Joel Klumpp at (512) 239-4453 or by e-mail at joel.klumpp@tceq.texas.gov or Vera Poe at (512) 239-6988 or by e-mail at vera.poe@tceq.texas.gov.

Sincerely,



Joel Klumpp, Team Leader
Technical Review and Oversight Team
Plan & Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality



Vera Poe, P.E., Team Leader
Utilities Technical Review Team
Plan & Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality



Linda Brookins, Director
Water Supply Division
Office of Water
Texas Commission on Environmental Quality