

Mr. Russell Schreiber, P.E.

Page 4 of 4

August 5, 2014

All liquid chemicals must have approved containment, all chemical injection solutions must be absent of any cross connections or potential for back flow, and the system must have documentation that the TCEQ has either approved the disinfection facilities, or allowed those facilities to be constructed without written approval. Additionally, all chemical storage and feed facilities must comply with 30 TAC §290.42(f)(2). All chemicals used must be certified under American National Standards Institute/National Sanitation Foundation (ANSI/NSF) Standard 60. This is consistent with the requirement that all chemicals used in treatment of water supplied by public water systems must conform to ANSI/NSF Standard 60 for direct additives. Conformance with these standards must be obtained by certification of the product by an organization accredited by ANSI as specified in 30 TAC §290.42(j).

All exceptions are subject to periodic review and may be revoked or amended if warranted. A copy of this letter and all related monitoring data must be maintained with the water system's records for as long as this exception is in effect. These records must be made available to TCEQ staff upon request.

Please note that this exception is not intended to waive compliance with any other TCEQ requirement in 30 TAC Chapter 290. This exception cannot be used as a defense in any enforcement action resulting from noncompliance with any other requirement of 30 TAC Chapter 290.

If you have questions concerning this letter, or if we can be of additional assistance, please contact Mr. David Simons, P.E., by e-mail at david.simons@tceq.texas.gov, or by telephone at (512) 239-3154, or by correspondence at the following address:

Technical Review & Oversight Team (MC 159)
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

Sincerely,



Joel Klumpp, Team Leader
Technical Review & Oversight Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality

JPK/dfs

Enclosures

Enclosure 1: Public Notice Materials

Enclosure 2: Monitoring Plan Alert and Action Levels

cc: Honorable Glenn Barham, Mayor, City of Wichita Falls, P.O. Box 1431, Wichita Falls, TX 76307-1431