

From: David Sloan
Sent: Wed, 24 Jul 2013 10:51:11 -0500
To: Russell Schreiber; daniel.nix@wichitafallstx.gov
Cc: Kerry D. Maroney
Subject: Re: Removal Credit

Russell: Sorry I missed your call yesterday. I'm in Utah and my service is pretty spotty. The Crypto/Giardia testing required by the TCEQ is the standard type with its delayed results. There is a component of the pending TWDB research grant to compare PCR test methods (with near real-time results) but this would not be for compliance.

Connected by DROID on Verizon Wireless

-----Original message-----

From: Russell Schreiber <russell.schreiber@wichitafallstx.gov>
To: Daniel Nix <daniel.nix@wichitafallstx.gov>, David Sloan <DWS@freese.com>
Cc: "Kerry D. Maroney" <kdm@bmiwf.com>
Sent: Tue, Jul 23, 2013 21:31:03 GMT+00:00
Subject: Re: Removal Credit

David

I noticed that CRMWD is only now beginning to perform Crypto and Giardia testing. Can you tell us what method they are using and is it a real-time method. To be more exact, how long before the sample results are available? All the methods we are aware of that are approved by the EPA require a minimum of 2 to 4 weeks.

Thanks

Russell Schreiber P.E
Director of Public Works
City of Wichita Falls Texas
940 761 7477

On Fri, Jul 19, 2013 at 3:42 PM, Daniel Nix
<daniel.nix@wichitafallstx.gov<mailto:daniel.nix@wichitafallstx.gov>> wrote:
FYI

----- Forwarded message -----

From: David Sloan <DWS@freese.com<mailto:DWS@freese.com>>
Date: Fri, Jul 19, 2013 at 3:28 PM
Subject: RE: Removal Credit
To: Daniel Nix <daniel.nix@wichitafallstx.gov<mailto:daniel.nix@wichitafallstx.gov>>

We have not had explicit log removal requirements. Pilot testing showed that after MF/RO treatment, there was no detection of Crypto, Giardia or Virus. Based on that, in 2010 they considered the treatment to be adequate, provided all the pilot conditions were met. Included in that was a requirement for a free chlorine residual of 1.0 mg/l in the effluent (our source water), although it was never actually free chlorine. When we went to document the UV treatment in lieu of the free chlorine requirement, they imposed a 4-log virus inactivation requirement documented by the UV system in lieu of the free chlorine in the source water. My understanding is that the MF system can provide a 4-log Crypto removal, but that has not been an explicit requirement. We will be conducting monthly Crypto and Giardia for 24 months beginning this fall.

Obviously, in the CRMWD case, the log removals are in addition to those provided by the surface water treatment plants which receive the blended water.

David Sloan / Freese and Nichols, Inc.

From: Daniel Nix [<mailto:daniel.nix@wichitafallstx.gov><<mailto:daniel.nix@wichitafallstx.gov>>]
Sent: Friday, July 19, 2013 2:25 PM
To: David Sloan
Subject: Removal Credit

Can you tell me what the TCEQ is requiring for log removal of Cryptosporidium, Giardia and Virus at Big Spring? For us (so far) they are requiring 5.5 log removal of Cryptosporidium, 7 log for Giardia and 9 log for Virus. How did the TCEQ set the log removals for Big Spring? Was it based on historical concentrations coming out of the Wastewater Effluent?

--

Daniel K. Nix
Public Utilities Operations Manager
City of Wichita Falls
Physical Address: 4801 Big Ed Neal Drive, Wichita Falls, Texas 76310
Mailing Address: P.O. Box 1431, Wichita Falls, Texas 76307
940-691-1153<tel:940-691-1153> FAX: 940-691-4121<tel:940-691-4121>
Daniel.Nix@wichitafallstx.gov<mailto:Daniel.Nix@wichitafallstx.gov>
http://1.bp.blogspot.com/-C9N5qx0HKA/Tf-D-t3xj_I/AAAAAAAAAH6E/IFL8aQx5ZHU/s1600/Wichita+Falls+Logo.jpg
Those who have the privilege to know have the duty to act. ~Albert Einstein

Please consider the environment before printing this message.

This electronic mail message is intended exclusively for the individual or entity to which it is addressed. This message, together with any attachment, may contain the sender's organization's confidential and privileged information. The recipient is hereby notified to treat the information as confidential and privileged and to not disclose or use the information except as authorized by sender's organization. Any unauthorized review, printing, retention, copying, disclosure, distribution, retransmission, dissemination or other use of, or taking of any action