

From: Joel Klumpp
Sent: Wed, 25 Feb 2015 21:22:15 +0000
To: David Sloan
Cc: Linda Brookins; Russell Schreiber (Wichita Falls); Kerry D. Maroney; Daniel Nix (Wichita Falls); Shawn Garcia; Mark Southard (mark.southard@wichitafallstx.gov); Craig Stowell; Vera Poe; Marlo Berg; Brad Castleberry (bcastleberry@lglawfirm.com)
Subject: RE: Wichita Falls DPR Continuation

Mr. Sloan,

Thank you for your email which requests an extension of the TCEQ's conditional approval of the City of Wichita Falls' Emergency Temporary DPR Project. We understand the critical role that the DPR project is providing to extend the City's water supply. The City may continue operation of the Emergency Temporary DPR Project under the conditions of the TCEQ letter dated August 5, 2014 until March 31, 2015.

Thank you for your submittal of the documentation for the City's new UV disinfection system. We look forward to receiving the additional information requested for that submittal. Once we receive the requested information, TCEQ staff can complete their review of the submittal and prepare a formal response. Our response will address your request to have conditional approval for operation of the City's Emergency Temporary DPR Project extended until February 29, 2016 and Mr. Schreiber's question from his email earlier today regarding the duration of TCEQ's conditional approval.

Per our meeting on January 14, 2015, we look forward to receiving your submittal regarding proposed modifications to the Cypress Water Treatment Plant/DPR Project to include water from Lake Kemp.

If you have any questions or if I can be of assistance, please don't hesitate to contact me.

Sincerely,

Joel

Joel Klumpp | Manager | Plan and Technical Review Section | TCEQ

12100 Park 35 Circle, Bldg. F | Austin, Texas 78753 | ☎ (512) 239-4453 Fax: (512) 239-6050 | ✉
Joel.Klumpp@tceq.texas.gov

From: David Sloan [mailto:DWS@freese.com]
Sent: Wednesday, February 25, 2015 10:51 AM
To: Joel Klumpp; Craig Stowell; Vera Poe; Marlo Berg
Cc: Linda Brookins; Russell Schreiber (Wichita Falls); Kerry D. Maroney; Daniel Nix (Wichita Falls); Shawn Garcia; Mark Southard (mark.southard@wichitafallstx.gov)
Subject: Wichita Falls DPR Continuation
Importance: High

Joel: The City of Wichita Falls began full operation of their new UV disinfection system on the DPR treatment facility at the Cypress WTP on February 13, 2015. This operation includes full recording of required status and calculation of log reduction for *Cryptosporidium* in accordance with the stipulated requirements. We submitted documentation for this on February 18, and received a request for

additional information from Craig Stowell on February 23. Everyone involved is working to bring this to completion as quickly as possible, but the current authorization is through the end of February, and the City wants to be sure there is no cause for interruption of this critical water supply source.

We expect to submit supplemental programming information from Trojan by tomorrow, February 26, and believe this is the only documentation lacking. However, the city understandably would like to have a contingency plan in place to allow continued operation in the event formal approval of the UV installation is not in place by this Saturday.

We appreciate the continued priority TCEQ has placed on this situation. Please contact me if we need to discuss this.

Sincerely,

DAVID W. SLOAN, P.E., BCEE
SENIOR PROCESS ENGINEER
BOARD CERTIFIED ENVIRONMENTAL ENGINEER



WATER / WASTEWATER TREATMENT & REUSE
4055 INTERNATIONAL PLAZA, SUITE 200 | FORT WORTH, TX, 76109
817 735 7277 VOICE | 817 528 4442 CELL
EMAIL: dws@freese.com

This electronic mail message is intended exclusively for the individual or entity to which it is addressed. This message, together with any attachment, may contain the sender's organization's confidential and privileged information. The recipient is hereby notified to treat the information as confidential and privileged and to not disclose or use the information except as authorized by sender's organization. Any unauthorized review, printing, retention, copying, disclosure, distribution, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited. If you received this message in error, please immediately contact the sender by reply email and delete all copies of the material from any computer. Thank you for your cooperation.