From: David Sloan
Sent: Wed, 22 Apr 2015 13:49:38 +0000
To: Craig Stowell
Cc: Marlo Berg; Daniel Nix (Wichita Falls); Vera Poe; Joel Klumpp
Subject: RE: Wichita Falls DPR UV SOP Updates

Thanks, Craig. We are working to get this resolved quickly.

DAVID SLOAN / FREESE AND NICHOLS, INC.

From: Craig Stowell [mailto:Craig.Stowell@tceq.texas.gov]
Sent: Wednesday, April 22, 2015 8:21 AM
To: David Sloan
Cc: Marlo Berg; Daniel Nix (Wichita Falls); Vera Poe; Joel Klumpp
Subject: RE: Wichita Falls DPR UV SOP Updates

David,

Important reminder, we need this document ASAP because we need it to finish our letter for the Lake Kemp water use submittal.

Craig A. Stowell, P.E.

Texas Commission on Environmental Quality
Water Supply Division
Utilities Technical Review Team, MC-159
P.O. Box 13087
Austin, Texas 78711-3087
Tel. 512-239-4633

How is our customer service? Fill out our online customer satisfaction survey at www.tceq.texas.gov/customersurvey.

From: Craig Stowell
Sent: Monday, April 20, 2015 12:52 PM
To: 'David Sloan'
Cc: Marlo Berg; 'Daniel Nix (Wichita Falls)'; vpoe (vera.poe@tceq.texas.gov)
Subject: RE: Wichita Falls DPR UV SOP Updates

David, After our small discussion at the conference I realized you may not understand what I am asking for. Daniel and Mark have an internal document called Alarms and Shutdown Conditions that was approved as part of the DPR. It is sort of like an SOP that guide them on each alarm and the conditions for shutdown. It needs to be modified to incorporate the UV boundary condition alarms as applicable. Call me if you have any questions.

Craig A. Stowell, P.E.

Texas Commission on Environmental Quality
Water Supply Division
Utilities Technical Review Team, MC-159
P.O. Box 13087
Austin, Texas 78711-3087
Tel. 512-239-4633

How is our customer service? Fill out our online customer satisfaction survey at www.tceq.texas.gov/customersurvey.

From: Craig Stowell
Sent: Wednesday, April 08, 2015 3:50 PM
To: 'David Sloan'
Cc: Marlo Berg; Daniel Nix (Wichita Falls)
Subject: RE: Wichita Falls DPR UV SOP Updates

David, condition 6 of my letter dated March 10, 2015 required that the Alarm and Shutdown Conditions must be revised to include an alarm for each of the UV boundary conditions. Please submit documentation of the alarms.

Craig A. Stowell, P.E.

Texas Commission on Environmental Quality
Water Supply Division
Utilities Technical Review Team, MC-159
P.O. Box 13087
Austin, Texas 78711-3087
Tel. 512-239-4633

How is our customer service? Fill out our online customer satisfaction survey at www.tceq.texas.gov/customersurvey.

From: David Sloan [mailto:DWS@freese.com]
Sent: Wednesday, April 01, 2015 1:35 PM
To: Craig Stowell
Cc: Joel Klumpp; Russell Schreiber (Wichita Falls); Daniel Nix (Wichita Falls); Mark Southard (mark.southard@wichitafallstx.gov); Shawn Garcia
Subject: Wichita Falls DPR UV SOP Updates

Craig: The City of Wichita Falls has updated their UV disinfection SOPs, as attached. The updates include monthly verification of the UV sensor against a calibrated reference sensor as required in your letter dated March 10, 2015. Please contact me if you have any questions regarding the updated SOPs.

Reference: Plan Review Log No. P-02182015-112
Wichita County
CN600129316; RN105598759

Regards,

DAVID W. SLOAN, P.E., BCEE
SENIOR PROCESS ENGINEER
BOARD CERTIFIED ENVIRONMENTAL ENGINEER

WATER / WASTEWATER TREATMENT & REUSE
4055 INTERNATIONAL PLAZA, SUITE 200 | FORT WORTH, TX, 76109
817 735 7277 VOICE | 817 528 4442 CELL
EMAIL: dws@freese.com

This electronic mail message is intended exclusively for the individual or entity to which it is addressed. This message, together with any attachment, may contain the sender's organization's confidential and privileged information. The recipient is hereby notified to treat the information as confidential and privileged and to not disclose or use the information except as authorized by sender's organization. Any unauthorized review, printing, retention, copying, disclosure, distribution, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited. If you received this message in error, please immediately contact the sender by reply email and delete all copies of the material from any computer. Thank you for your cooperation.